



CONFIRMATION

According the Test report No 10976

This is to certify that the company:

PLESSIO S.A.

INDUSTRIAL AREA OF
THESSALONIKI GREECE


Which manufactures fireproof doors, carried out a fire-resistance test on a complete timber door set at the **Laboratory for Heat Transfer and Fuel Technology of the Ghent University in Belgium.**

Xenia RF30'


The test procedure follows the Belgian standard **NBN 713.020**

The door set was intact for all criteria during 51 minutes.

Date of test: 2003-08-19



Ing. S. TEIRLINCK



Prof. dr. ir. P. VANDEVELDE

This confirmation does not replace the complete test report N° 10976, which is available on request from the manufacturer.